

From: Conetta, Benny  
Sent: Tuesday, July 23, 2013 12:35 PM  
To: Mannino, Pietro  
Cc: Romanowski, Larisa; Darpinian, Amy F NWK  
Subject: FW: Dewey Landfill site visit 7/15/13 (UNCLASSIFIED)

fyi

Ben Conetta  
USEPA Region 2  
290 Broadway - 19th Floor  
N.Y., N.Y. 10007  
T:212-637-3030  
F:212-637-4339

-----Original Message-----

From: Leonard, Timothy NAN02 [<mailto:Timothy.Leonard@usace.army.mil>]  
Sent: Monday, July 22, 2013 3:12 PM  
To: Conetta, Benny  
Cc: Cimorelli, Thomas A NAN02; Pillsworth, Timothy P NAN02; Deetz, Scott NAN  
Subject: RE: Dewey Landfill site visit 7/15/13 (UNCLASSIFIED)

Classification: UNCLASSIFIED  
Caveats: NONE

Ben

Conducted a site visit today accompanied by Tyler (Arcadis).

Ongoing work activities observed during visit were;

- 1) Continued stone backfill placement/compaction inside bld in addition to fill around bld exterior. Stub outs for elec conduits, force main and discharge were being installed. Atlantic Testing technician on site during visit conducting in-place moisture density testing with Nuke guage for backfill. No issues noted.
- 2) Observed delivery of the steel for the treatment bld. Fabrication expected to commence mid week. No issues noted.
- 3) Discussed permits/access issue with regard to Meade Road crossing and discharge line with Tyler. He was not aware of any changes or approvals as of yet but informed me it was discussed at their weekly call. As they are ready to commence installation of this line resolution of the access permit should be at the top of their/our list of concerns. If it drags on this will quickly be a cause for delays.
- 4) No changes to note regarding trucking issue.

Next site visit planned is for 7/29/13.

Please call if you have any questions.

Timothy P. Leonard, PE  
Project Engineer, CENAN-CO-WP  
West Point Resident Office  
office:845-938-8310

fax:845-938-3863

Classification: UNCLASSIFIED  
Caveats: NONE

Classification: UNCLASSIFIED  
Caveats: NONE